

Table R402.1.2: Maximum Assembly U-Factors and Fenestration (Window) Requirements

	Climate Zone		
	3	5	6
Fenestration U-Factor	0.30	0.30	0.30
Skylight U-Factor	0.55	0.55	0.55
Glazed Fenestration SHGC	0.25	NR	NR
Ceiling U-Factor	0.026	0.024	0.024
Wood Frame Wall U-Factor	0.060	0.045	0.045
Mass Wall U-Factor	0.098	0.082	0.060
Floor U-Factor	0.047	0.033	0.033
Basement Wall U-Factor	0.091	0.050	0.050
Crawl Space Wall U-Factor	0.136	0.055	0.055